



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Riggall St 61**

61 Riggall Street Broadmeadows

Contract No: P3608

## Callouts ID:

Date of Call: 16-10-2018 6:30:00

Time of Arrival: 16-10-2018 7:00:00

Rectification Time: 16-10-2018 8:00:00

Time of Departure: 16-10-2018 8:10:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** gnd

**Call Description:** OOO

**Order Number:** 1

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Faulty Brakes

**Work Action (CORRECTION):** See Work description

**Work Description:** The thread between the brake plunger and the activation shaft had broken a new one was made and installed

**Part Required:** Threaded shaft two nuts and mushroom head washer

**Service Technician**

Phil Dodsworth

**Report Customer**

yes