



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Melrose St 159, North Melbourne
159 Melrose St North Melbourne
Contract No: P3429

Callouts:

Date of Call: 09-11-2018 0:19:00
Time of Arrival: 09-11-2018 0:55:00
Rectification Time: 09-11-2018 2:30:00
Time of Departure: 09-11-2018 3:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 5

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Relay

Work Action (CORRECTION): See Work description

Work Description: Release passenger \r\nFound bad plug connection on pt4x relay on.brake module board\r\nAlso strip and clean pt4x relay\r\nFault cleared\r\noperation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer