



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Metro Laverton

Metro Laverton Station Laverton

Contract No: P3587

Maintenance ID:

Date of Call: 18-10-2018

Time of Arrival: 9:00:00

Time of Departure: 15:30:00

Maintenance Details

Maintenance Description: Routine service \r\nReplace 1x faulty tube lift 3\r\nreplace 1x faulty ups lift 3\r\nrelearn shaft data lift 1&4\r\nrun counts 3-364363 4-1097536

Maintenance Task	Lift 1	Lift 2	Lift 3	Lift 4
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y	Y
Test all car safties	Y	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y	Y
Check tuning ajustments	Y	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y	Y
Check and ajust car & cwt guide shoes	Y	Y	Y	Y
Check all safety switches, limits in lift well	Y	Y	Y	Y
check brake operation rope brake and associated equipment	Y	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y	Y
Clean lift well equipment	Y	Y	Y	Y
Report any major rapirs	Y	Y	Y	Y
Test Lift Communications	Y	Y	Y	Y

Service Technician

Matt Grieger

Customer Email