



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Riversdale Rd 917-919, Surrey Hills
917-919 Riversdale Rd Surrey Hills
Contract No: P3407

Callouts: 22285

Date of Call: 14-11-2018 14:21:39
Time of Arrival: 15-11-2018 8:45:00
Rectification Time: 15-11-2018 9:30:00
Time of Departure: 15-11-2018 9:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): 0

Call Description: 2 x lights out in lift

Order Number: CWO0235776

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Emergency light unit board required replacing.\r\nAlso emergency light unit is only designed to run halogen globes, reported to property manager

Part Required: New elu board

Service Technician

Zane Tregurtha

Report Customer

0