



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

La Trobe St 171, Melbourne
171 La Trobe St Melbourne
Contract No: P3391

Callouts: 22303

Date of Call: 16-11-2018 9:15:00
Time of Arrival: 16-11-2018 9:40:00
Rectification Time: 16-11-2018 10:45:00
Time of Departure: 16-11-2018 11:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 6

Call Description: lift is out of service

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: 6th floor landing door jamming on door frame. Re adjusted landing door shoes

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

-