



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Potter Street 12-16, Dandenong
12-16 Potter Street Dandenong
Contract No: P3646

Callouts:

Date of Call: 06-12-2018 10:00:00
Time of Arrival: 06-12-2018 10:00:00
Rectification Time: 06-12-2018 10:30:00
Time of Departure: 06-12-2018 10:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): g

Call Description: Lift shut down on 5.12 due to water ingress

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Check landings and lift for dampness/water and reset rcbo.\r\nLift did not fault. Return to service

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0