



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Gordon St 127, Footscray
127 Gordon St Footscray
Contract No: P3469

Callouts:

Date of Call: 27-11-2018 2:25:00
Time of Arrival: 27-11-2018 2:45:00
Rectification Time: 27-11-2018 3:00:00
Time of Departure: 27-11-2018 3:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): G

Call Description: Lift stopped doors closed

Order Number: 15777

DESCRIPTION OF WORK

Fault Found (CAUSE): Overload Tripped

Work Action (CORRECTION): See Work description

Work Description: CP2 tripped- Re-wire circuit breaker and reset lift.

Part Required: No Parts Required

Service Technician

Daniel Barry

Report Customer

.