



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Barkly St 250, Footscray
250 Barkly St Footscray
Contract No: P3309

Callouts:

Date of Call: 04-01-2019 18:15:00
Time of Arrival: 04-01-2019 18:25:00
Rectification Time: 04-01-2019 19:00:00
Time of Departure: 04-01-2019 19:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 4

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Car doors out of adjustment suspect been hit
Car and landing doors pried and wedged open causing 14 landing doors to be out of adjustment
Re aligned and straightened both sets of doors
Test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer