

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Metro St Albans Station

Main Road St Albans Road St Albans

Contract No: P3638

Callouts: 22480

Date of Call: 04-12-2018 15:59:41 Time of Arrival: 04-12-2018 17:15:00 Rectification Time: 04-12-2018 17:25:00 Time of Departure: 04-12-2018 17:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): platform level

Call Description: doors open on platform level.\r\nSite Contact: Deepika\r\n96108571

Order Number: 659859

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): Remove Object From Doors

Work Description: Error code 54 caused due to rock in door track. Removed and cleaned track ran and tested ok

Part Required: No Parts Required

Service Technician Report Customer

Brad Stellini