



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

4/4 Illawara Crescent
4/4 Illawara Crescent Toorak
Contract No: P3603

Callouts ID:

Date of Call: 21-10-2018 16:28:00
Time of Arrival: 22-10-2018 9:30:00
Rectification Time: 22-10-2018 10:30:00
Time of Departure: 22-10-2018 10:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: Lift ooo from weekend \r\nOrganised to come monday

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift ooo from doors being forced open after lift stopped.\r\nLift ran and did not fault.\r\nChecked locks and all relays and contactors.\r\nReplaced contactor.\r\nMonitored for 1hr did not fault

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0