



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

William Angliss Institute (Building B - 555 La Trobe St)
555 La Trobe St Melbourne (Building B)
Contract No: P3175

Callouts: 22267

Date of Call: 13-11-2018 9:30:49
Time of Arrival: 13-11-2018 10:30:00
Rectification Time: 13-11-2018 11:35:00
Time of Departure: 13-11-2018 11:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): basement

Call Description: dumb waiter lift out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Over traveled in down direction \r\nchecked brake function \r\nadjusted brake and checked operation \r\nreturned lift to service.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Paul 0411 112 254