



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

1-3 Railway Place
1-3 Railway Place Cremorne
Contract No: 3572

Callouts:

Date of Call: 15-12-2018 19:48:00
Time of Arrival: 16-12-2018 11:00:00
Rectification Time: 16-12-2018 11:00:00
Time of Departure: 16-12-2018 11:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s):

Call Description: Lift 1 playing up

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): Check Operation

Work Description: Both lifts roa\r\nerror cant close on l7 where found screw stuck in door track possible cause when error was logged\r\nFriday night water had flooded lift foyer on ground and was signs of water in lift controller

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer