



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Victoria Hotel
215 Lt Collins St Melbourne
Contract No: P3234

Callouts ID: 21984

Date of Call: 12-10-2018 14:09:01
Time of Arrival: 12-10-2018 14:25:00
Rectification Time: 12-10-2018 15:00:00
Time of Departure: 12-10-2018 15:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 6

For Floor(s): 1

Call Description: Stuck on Level 1

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift on level 1 \r\nlanding door error\r\nfound faulty landing door guide shoe\r\nreplaced checked operation ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Vikas 9669 0000