



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Cambridge St 134, Collingwood
134 Cambridge St Collingwood
Contract No: P3195

Callouts:

Date of Call: 13-11-2018 17:25:00
Time of Arrival: 13-11-2018 18:00:00
Rectification Time: 13-11-2018 18:10:00
Time of Departure: 13-11-2018 18:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): 2

Call Description: Lift swp on level 2

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Released stuck passenger lift error code 20 checked associated components ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

.