



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Sargood House
61-73 Flinders Lane Melbourne
Contract No: P3190

Callouts: 22681

Date of Call: 20-12-2018 14:34:26
Time of Arrival: 21-12-2018 15:00:00
Rectification Time: 21-12-2018 17:00:00
Time of Departure: 21-12-2018 17:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 3

For Floor(s): B

Call Description: SWP

Order Number: ..

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: High resistance door lock on de-commissioned 3rd floor landing doors cleaned and adjusted

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

tk 0434938149