



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Simmons St 2, South Yarra  
2 Simmons St South Yarra  
Contract No: P3461

## Callouts:

Date of Call: 02-01-2019 22:52:00  
Time of Arrival: 02-01-2019 23:35:00  
Rectification Time: 03-01-2019 0:40:00  
Time of Departure: 03-01-2019 0:45:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** 5

**Call Description:** lift out of order

**Order Number:** 16399

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Landing door aircord broken on level 5\r\nreplaced cable checked operation.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Barry