



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Queen St 221, Melbourne  
221 Queen St Melbourne  
Contract No: P3387

**Callouts ID: 22116**

Date of Call: 26-10-2018 12:46:31  
Time of Arrival: 26-10-2018 13:25:00  
Rectification Time: 26-10-2018 15:05:00  
Time of Departure: 26-10-2018 15:10:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1,2

**For Floor(s):** .

**Call Description:** Lift 1 - Out of Order\r\nLift 2 - No lighting - Pitch black

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** lift 2 lights rcd tripped reset checked operation rectified by construction,\r\nlift 1 error 36 checked output contactor checked auxiliary contact tested ok monitoring fault.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Jimmy 0408 172 877