



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Henry St 71, Kensington
71 Henry St Kensington
Contract No: P3503

Callouts ID:

Date of Call: 20-10-2018 9:34:00
Time of Arrival: 20-10-2018 10:20:00
Rectification Time: 20-10-2018 10:45:00
Time of Departure: 20-10-2018 11:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1,2

For Floor(s):

Call Description: Both lifts ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Both lifts roa\r\nFound inductor sticking on lhs lift\r\nWas getting stuck every run\r\nCleaned and freed up inductor\r\nTested thoroughly with security guard couldnt get to fault again\r\nChecking office for spare inductor\r\n

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer