



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

St Kilda Rd 437, Melbourne
437 St Kilda Rd Melbourne
Contract No: P3104

Callouts: 22157

Date of Call: 01-11-2018 13:00:00
Time of Arrival: 01-11-2018 13:15:00
Rectification Time: 01-11-2018 13:15:00
Time of Departure: 01-11-2018 13:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 2

For Floor(s): B

Call Description: lift 2 doors are crunching when opening and closing

Order Number: CWO02325812

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found astragal had slipped down and was dragging on the car sill. Adjust and secure.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.