



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

City Gate Hotel/Doubletree
270 Flinders St Melbourne
Contract No: P3103

Callouts:

Date of Call: 31-10-2018 7:19:00
Time of Arrival: 31-10-2018 8:15:00
Rectification Time: 31-10-2018 12:15:00
Time of Departure: 31-10-2018 12:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 10

Call Description: lift 2 out of order level 10

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 2 brake error checked and readjusted brakes, \r\nchecked lifts 1 and 3 tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

josh