



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Temple Court
422 Collins St Melbourne
Contract No: P3327

Callouts:

Date of Call: 08-12-2018 14:40:00
Time of Arrival: 08-12-2018 17:30:00
Rectification Time: 08-12-2018 18:10:00
Time of Departure: 08-12-2018 18:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): .

Call Description: lift out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: machine fault\r\nchecked motor contactors and brake\r\nreplaced coil pack on motor contactor\r\nchecked operation tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

cyril