



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel  
131 King St Melbourne  
Contract No: P3249

**Callouts ID: 22111**

Date of Call: 26-10-2018 8:49:17  
Time of Arrival: 26-10-2018 9:10:00  
Rectification Time: 26-10-2018 12:05:00  
Time of Departure: 26-10-2018 12:30:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** ground floor

**Call Description:** lift is stuck on ground floor

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Door close limit fault on door operator, supplied and fitted new car door operator controller, checked operation ok.

**Part Required:** YS-K32

**Service Technician**

Robert Pelle

**Report Customer**

Jeremy