



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elizabeth St 191, Richmond (Building B)
191 Elizabeth St Richmond (Building B)
Contract No: P3547

Callouts ID:

Date of Call: 19-10-2018 17:16:00
Time of Arrival: 22-10-2018 8:10:00
Rectification Time: 22-10-2018 9:50:00
Time of Departure: 22-10-2018 10:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): All

Call Description: Lift Shutdown Friday night

Order Number: 15231

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Adjust Brake/Switches

Work Description: Return from shutdown. Brake not dropping out reliably. Strip, clean and assess brake assembly condition, ok. Lubricate all pivot points, adjust spring tension, brake lift and air-gap. Conduct multiple full speed emergency stops to test brake operation, all tests within specifications at time of testing. \r\n\r\n lift to test. Ok.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Jacobs