



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts:

Date of Call: 06-11-2018 12:08:00
Time of Arrival: 06-11-2018 15:10:00
Rectification Time: 06-11-2018 15:30:00
Time of Departure: 06-11-2018 15:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 2

For Floor(s):

Call Description: Water coming in lift car

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Water coming into lift shaft through windows in lift shaft\r\nNeeds to be addressed and covered\r\nSigns on water all over car top including o
inductor stack, car top fans, car door operator.\r\nLift return to service but follow up visit required

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer