



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Werribee Mansion (Sofitel Hotel & Spa)
0 K Rd Werribee
Contract No: P3088

Callouts:

Date of Call: 02-12-2018 13:16:00
Time of Arrival: 02-12-2018 14:14:00
Rectification Time: 02-12-2018 14:35:00
Time of Departure: 02-12-2018 15:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: Lift OOO on unknown level

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Adjusted door cam to allow for smooth dropping of locks. Run and tested. Returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.