



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

William Angliss Institute (Building C - 555 La Trobe St)
555 La Trobe St Melbourne (Building C)
Contract No: P3175

Callouts: 22491

Date of Call: 05-12-2018 16:08:11
Time of Arrival: 05-12-2018 16:45:00
Rectification Time: 05-12-2018 17:10:00
Time of Departure: 05-12-2018 17:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): ground floor

Call Description: lift is stuck on ground floor

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift had overtravelled in the down direction at ground floor. Bridged overtravel contacts, drove lift up on inspection control, returned to service. Monitored, tested ok.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

*