



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Gordon St 127, Footscray
127 Gordon St Footscray
Contract No: P3469

Callouts:

Date of Call: 19-11-2018 19:50:00
Time of Arrival: 19-11-2018 20:10:00
Rectification Time: 19-11-2018 20:15:00
Time of Departure: 19-11-2018 20:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 12

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Main Circuit Braker Tripped

Work Action (CORRECTION): See Work description

Work Description: Ard isolation cb tripped\r\nCheck for possible causes and found faulty power supply in ard unit\r\nTo be replaced

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer