



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Box Hill Town Hall
1022 Whitehorse Rd Box Hill
Contract No: 3472 - B505

Callouts ID: 22023

Date of Call: 18-10-2018 11:39:34
Time of Arrival: 18-10-2018 10:30:00
Rectification Time: 18-10-2018 11:25:00
Time of Departure: 18-10-2018 11:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): 1

Call Description: Main Foyer lift quite often stops with a sudden jolt at both lower ground level and level 1

Order Number: 124468

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Bleed ram and re position ram stages.\r\nIf continues may have to clean and disassemble valve block.\r\nWill continue to monitor

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0