

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Batman's Hill on Collins
623 Collins Street Melbourne
Contract No: P3681

Callouts: 22360

Date of Call: 21-11-2018 13:59:11 Time of Arrival: 21-11-2018 14:20:00 Rectification Time: 21-11-2018 14:55:00 Time of Departure: 21-11-2018 15:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 6

For Floor(s): .

Call Description: lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Reported doors opening slowly \r\nreplaced car door operator PCB as discussed \r\nchecked operation \r\nmonitoring fault.

Part Required: AMD car door operator PCB

Service Technician Report Customer

Robert Pelle Yani 0400060448