



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts: 22643

Date of Call: 17-12-2018 12:54:10
Time of Arrival: 17-12-2018 14:45:00
Rectification Time: 17-12-2018 16:20:00
Time of Departure: 17-12-2018 16:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1,2

For Floor(s): 2

Call Description: lift 1 has button missing, lift 2 has stopped on level 5

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Replaced car button in lift 1 level 1 \r\n car button was vandalized,\r\n lift 2 main board error switched off for the night.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Dennis 0396294171