



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Derby St 56, Kensington
56 Derby St Kensington
Contract No: P3419

Callouts: 22492

Date of Call: 06-12-2018 9:05:00
Time of Arrival: 06-12-2018 9:10:00
Rectification Time: 06-12-2018 9:40:00
Time of Departure: 06-12-2018 9:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Closed

For Lift(s): 1

For Floor(s): 4

Call Description: lift doors wont open on level 4

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Repair door pickup roller.

Part Required: No Parts Required

Service Technician

mat tehan

Report Customer

jake 401776045