



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Kew Pumping Station - Melbourne Water
- Bourke Road Kew
Contract No: B3747

Maintenance ID:

Date of Call: 16-10-2018
Time of Arrival: 9:30:00
Time of Departure: 10:20:00

Maintenance Details

Maintenance Description: Regular service \r\nGear box seal leaky

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning ajustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and ajust car & cwt guide shoes	Y
Check pit equipment and check water for pit	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Zane Tregurtha

Customer Email

caroline@unitedlifts.com.au