



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Maintenance:

Date of Call: 28-12-2018
Time of Arrival: 8:30:00
Time of Departure: 11:30:00

Maintenance Details

Maintenance Description: Routine service and Hazard & Risk Assessment

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning adjustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check and adjust car & cwt guide shoes	Y	Y
Check all safety switches, limits in lift well	Y	Y
Check pit equipment and check water for pit	Y	Y
Clean lift well equipment	Y	Y
Check trailer flexes, attachments running clearance	Y	Y
Test Emergency Light Unit	Y	Y
Pit Clean Report	Y	Y
Test Lift Communications	Y	Y

Service Technician

James Wallace

Customer Email

LiftServices-02@jacobs.com