



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Dandenong
Metro Foster Street Dandenong
Contract No: W3677

Callouts:

Date of Call: 03-11-2018 10:00:00
Time of Arrival: 03-11-2018 10:28:00
Rectification Time: 03-11-2018 10:58:00
Time of Departure: 03-11-2018 11:38:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): G

Call Description: Lift out of order on ground

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lift at ground floor with doors open. Checked for any obstruction or deviation in door lock. Doors closing ok. Adjusted cam and lower door lock roller. Might be possible to increase the weight on aircord.\r\nRan and observed the lift for 50 minutes

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#