



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Metro Ginifer station
0 St Albans Road Ginifer
Contract No: P3639

Maintenance:

Date of Call: 14-12-2018
Time of Arrival: 13:30:00
Time of Departure: 15:30:00

Maintenance Details

Maintenance Description: Routine service \r\nWater in lift 1 pit reported to sean kerr\r\nSwap faulty ups on lift 2 with new\r\nRun counta 1-177561 2-147142

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check and ajust car & cwt guide shoes	Y	Y
Check all safety switches, limits in lift well	Y	Y
Check pit equipment and check water for pit	Y	Y
Clean lift well equipment	Y	Y
Report any major rapirs	Y	Y
Test Lift Communications	Y	Y

Service Technician

Matt Grieger

Customer Email