



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Maribyrnong City Council - Municipal Offices (61 Napier St, Footscray)
61 Napier St Footscray
Contract No: 3395

Callouts:

Date of Call: 05-11-2018 8:27:00
Time of Arrival: 05-11-2018 8:55:00
Rectification Time: 05-11-2018 9:15:00
Time of Departure: 05-11-2018 9:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift over top floor \r\nDrove lift down check and clean tape reader and sensors\r\nReturn to service and test operation \r\nAll ok couldnt get lift
fault

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer