



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton
141 Nicholson St Carlton
Contract No: P3118

Callouts:

Date of Call: 17-12-2018 14:10:00
Time of Arrival: 17-12-2018 14:34:00
Rectification Time: 17-12-2018 15:10:00
Time of Departure: 17-12-2018 15:18:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Closed

For Lift(s): 1

For Floor(s): G

Call Description: Lift out of order with doors closed.

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Landing doors not closing fully closed.\r\nAdjusted landing door rollers.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x