



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Caulfield Hospital
260 Kooyang Road Caulfield
Contract No: 3565

Callouts ID: 22003

Date of Call: 16-10-2018 12:10:37
Time of Arrival: 16-10-2018 14:30:00
Rectification Time: 17-10-2018 9:45:00
Time of Departure: 18-10-2018 9:54:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: lift stuck on lv 2

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift S2 000 on ground floor with fours closed, found two of the finger contacts broken in lower limit box, shut down overnight\r\nReplaced finger contacts in the morning and test lift operation

Part Required: Limit switch finger contacts

Service Technician

Dwain Sanderson

Report Customer

Ronda 9076 6000