



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wellington Street 240, Collingwood
240 Wellington Street Collingwood
Contract No: 3700

Callouts ID: 22005

Date of Call: 16-10-2018 13:15:49
Time of Arrival: 16-10-2018 16:03:00
Rectification Time: 16-10-2018 17:03:00
Time of Departure: 16-10-2018 17:03:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): 14

Call Description: call button on level 14 isn't working

Order Number: 15145

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift button smashed in and vandalised.

Part Required: 2x threaded screws re welded to station plate to secure button\r\n1x level 14 button

Service Technician

Marek Torrico

Report Customer

#