



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton
141 Nicholson St Carlton
Contract No: P3118

Callouts ID:

Date of Call: 25-10-2018 8:18:00
Time of Arrival: 25-10-2018 8:50:00
Rectification Time: 25-10-2018 9:20:00
Time of Departure: 25-10-2018 9:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 11

Call Description: Lift no.1 out of order.

Order Number: 15312

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lvl.10 door lock fault. Checked landing doors and door lock.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x