



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Bourke St 423, Melbourne  
423 Bourke St Melbourne  
Contract No: P3339

**Callouts: 22167**

Date of Call: 02-11-2018 12:01:05  
Time of Arrival: 02-11-2018 15:05:00  
Rectification Time: 02-11-2018 15:45:00  
Time of Departure: 02-11-2018 15:55:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** ground

**Call Description:** lift is out of order

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** UNT3 Error switch open \r\nlift on ground floor \r\nchecked magnetic switch checked clearances checked operation ok.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Ricky