



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Westall
Metro Westall Station Clayton
Contract No: P3588

Callouts:

Date of Call: 07-01-2019 3:55:00
Time of Arrival: 07-01-2019 4:40:00
Rectification Time: 07-01-2019 5:22:00
Time of Departure: 07-01-2019 5:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Lift 3

For Floor(s): g

Call Description: Lift 000 on g with doors open

Order Number: 02AA604563

DESCRIPTION OF WORK

Fault Found (CAUSE): Lift on Exclusive or Fire Service

Work Action (CORRECTION): See Work description

Work Description: Lift 3 000 with doors open on ground \r\nInspected lift doors all good checked all safeties all good, no faults in event log \r\nSwitched fire service
fob on landing and in car and lift returned to service

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

station master