



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Holm Park Recreation Reserve
100 Beconsfield-Emerdale Road Beconsfield
Contract No: P3488

Callouts: 22547

Date of Call: 10-12-2018 14:46:08
Time of Arrival: 10-12-2018 15:30:00
Rectification Time: 10-12-2018 16:30:00
Time of Departure: 10-12-2018 16:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: lift is out of order

Order Number: 24921

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Picked keys up and attended call.\r\nWould not take landing calls and not closing doord after car call placed.\r\nFound lift keyed on independ service,\r\nKey to off and lift operated as normal.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0