

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Swanston St 158, Melbourne
158 Swanston St Melbourne
Contract No: P3162

Callouts: 22286

Date of Call: 14-11-2018 14:55:00 Time of Arrival: 14-11-2018 15:35:00 Rectification Time: 14-11-2018 16:00:00 Time of Departure: 14-11-2018 16:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1
For Floor(s): 1

Call Description: lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Error 2 landing door fault,\r\nDoors open on level 1,\r\nchecked landings doors and lock clearances \r\nchecked operation,\r\nlift back in serv

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle