



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Toorak Rd 1155, Camberwell
1155 Toorak Rd Camberwell
Contract No: P3192

Maintenance:

Date of Call: 06-12-2018
Time of Arrival: 11:20:00
Time of Departure: 12:21:00

Maintenance Details

Maintenance Description: Regular service \r\nAlso adjusted and added magnet in shaft positioning to ensure proximity switches make good action

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning ajustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and ajust car & cwt guide shoes	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Zane Tregurtha

Customer Email

MarkSeater@allardshelton.com.au