



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

William Angliss Institute (Building C - 555 La Trobe St)
555 La Trobe St Melbourne (Building C)
Contract No: P3175

Callouts:

Date of Call: 09-11-2018 10:00:00
Time of Arrival: 09-11-2018 10:25:00
Rectification Time: 09-11-2018 10:55:00
Time of Departure: 09-11-2018 11:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): gnd floor

Call Description: OOO gnd floor

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Broken car door lock\r\nRepair and reassemble door lock

Part Required: No Parts Required

Service Technician

Phil Dodsworth

Report Customer

yes