



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wattletree Rd 62, Armadale
62 Wattletree Rd Armadale
Contract No: P3272

Callouts: 22635

Date of Call: 17-12-2018 9:13:08
Time of Arrival: 17-12-2018 12:30:00
Rectification Time: 17-12-2018 13:30:00
Time of Departure: 17-12-2018 14:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 1

Call Description: lift is playing up

Order Number: 088348

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift out of order without lock circuit.
Found car door veins holding landing locks up.
Door coupler had become loose and not pulling veins in to give required clearance.
Tighten and tested ok.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

chris 0430064629