



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Collins St 411, Melbourne
411 Collins St Melbourne
Contract No: P3236

Callouts:

Date of Call: 15-12-2018 8:10:00
Time of Arrival: 15-12-2018 8:25:00
Rectification Time: 15-12-2018 8:25:00
Time of Departure: 15-12-2018 8:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1,2

For Floor(s):

Call Description: Water in lift shaft

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Water in front of lift doors in basement \r\nWater in pit but only small amount\r\nPumps obviously working as looks like was more water yesterday

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer