



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Carlisle St 17, St Kilda
17 Carlisle St St Kilda
Contract No: P3417

Maintenance:

Date of Call: 30-11-2018
Time of Arrival: 11:05:00
Time of Departure: 11:45:00

Maintenance Details

Maintenance Description: Routine maintenance \r\nElu test pass at time of test \r\nNo phone line to the lift \r\nWater in pit

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean out controller ad check operation of various parts.	Y
Check tuning ajustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and ajust car & cwt guide shoes	Y
Check pit equipment and check water for pit	Y
Test Lift Communications	Y

Service Technician

Brad Stellini

Customer Email