



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Gill Apartments
213-219 A'Beckett St Melbourne
Contract No: P3598

Callouts: 22739

Date of Call: 31-12-2018 12:30:34
Time of Arrival: 31-10-2018 12:40:00
Rectification Time: 31-12-2018 12:55:00
Time of Departure: 31-12-2018 13:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: lift is out of order

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Reset Control System

Work Description: No error displayed. Checked door lock and landing doors. Checked safety circuit.\r\n

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

ann 0393264382